



महानगरपालिका, छत्रपती संभाजीनगर.

दुरध्वनी क्र. २३३३५३६-४० फॅक्स क्र. (०२४०) २३३१२१३
अग्निशमन विभाग दुरध्वनी क्र. २३३४०००, फॅक्स क्र. (०२४०) २३३१४४४

जा.क्र.मनपा/अशाद/ १९०/२०२३

दिनांक :- १७ /०५/२०२३

प्रति,

सचिव,

भोंडवे पाटील पब्लीक स्कुल,

प्लॉट नं ४९/पी, ५२/२/पी,

मौजे वडगाव कोल्हाटी ता जि.

छत्रपती संभाजीनगर


विषय:- अग्निशमन ना हरकत प्रमाणपत्र नुतनीकरण.

संदर्भ:- १. जा.क्र/मनपा/अशाद/ 1316 /2020, दि. 06/01/2020.

२. आपले पत्र 17/05/2023

उपरोक्त विषयी कळविण्यात येते की, आज दिनांक 17/05/2023 रोजी अग्निशमन विभागातर्फे स्थळपाहणी करण्यात आली. टेस्टिंग व रिफिलींग रिपोर्ट व स्थळपाहणी अहवालानुसार, अग्निशमन सुरक्षीततेच्या दृष्टीने करण्यात आलेली उपाय योजना व उपकरणे सुस्थितीत आहे. महाराष्ट्र फायर प्रिव्हेंशन अँड लाईफ सेफटी मेजर्स अँक्ट 2006 चे कलम 6/7 नुसार अग्निशमन उपकरणे प्रत्येक सहा महिन्याला तपासणी केलेला अहवाल नमुना ब (कलम 3 (3) व नियम 4(2) नुसार देणे आवश्यक आहे.

करीता महाराष्ट्र फायर प्रिव्हेंशन अँड लाईफ सेफटी मेजर्स अँक्ट 2006 चे कलम 03 नुसार व संदर्भिय पत्र क्र.1 अन्वये देण्यात आलेल्या अग्निशमन ना हरकत प्रमाणपत्राचे नुतनीकरण करण्यात येते. पुढील नुतनीकरण दि. 06/01/2024 पुर्वी करणे बंधनकारक आहे.


मुख्य अग्निशमन अधिकारी,
अग्निशमन विभाग,
महानगरपालिका,
छत्रपती संभाजीनगर.

प्रति,

1. परवाना विभाग, पोलिस आयुक्तालय, छत्रपती संभाजीनगर.
2. राज्य उत्पादन शुल्क कार्यालय, छत्रपती संभाजीनगर.
3. एम.आय.डी.सी. कार्यालय, छत्रपती संभाजीनगर.
4. परवाना विभाग, आरोग्य विभाग, महानगरपालिका, छत्रपती संभाजीनगर.



AURANGABAD MUNICIPAL CORPORATION
FIRE BRIGADE
TELEPHONE NO-2334000-40FAX No-2331444

Outward No:AMC/FIRE / 190 /2023

Date 17 / 05 /2023

FIRE SAFETY CERTIFICATE

Certified That the **Bhondwe Patil Public School, Gut No. 49/P & 52/2, At. Wadgaon Kolhati, Bajaj Nagar, Autangabad.** Comprised of basement (S) and (upper floors) owned/occupied by **Bhondwe Patil Public School** have complied with the fire prevention and fire safety requirements in accordance with rule of state / UT Fire service Rules, and Verified by the Officers concerned of fire service on **17/05/2023** in the presence of **shri. Hanuman Jagannath Bhondwe** and that the building / Premises is fit for occupancy upto **Classes Pre-Primary To 10th (X / XII)** with effect fromfor a period of year in accordance with rule and subject to compliance of specific conditions as appended.

1. 4.50/6.00 Mtr. Open space all around the building is provided for the movement of fire tender and which will carry 25 tons. weight capacity.
2. Overhead water tank 25000 lit. capacity with the Booster Pump-01 No. of suitable capacity for building is Provided.
3. Fire service inlet 02 Way -01 No. incoming is provided.
4. Main Staircase 2.00 Mtr & Fire Staircase of 1.50 Mtr Width is Provided.
5. 01 Down Commer having outlet on all floors with Hose pipe 01No / Branch-01 No is provided.
6. 09 Nos. Hose reel of 100 feet on all outlets is provided.
7. Fire Extinguisher of ABC -6Kg-06 Nos of suitable capacity / quantity is provided.
8. This Certificate shall be treated valid for a period of one year from the date of issue from Fire Noc.
9. Fire Noc must be renewed each year.

Issued on **17/05/2023** at **Bhondwe Patil Public School, Gut No. 49/P, 52/2, At. Wadgaon Kolhati, Autangabad.** by Strike out whichever is not applicable.


Chief Fire Officer
Fire Brigade
Municipal Corporation Aurangabad

To,

Secretary, Bhondwe Patil Public School, Gut No. 49/P, At. Wadgaon Kolhati, Autangabad

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand Cancelled and annulled due to Fire Noc must be renewed each year